



COLORADO DEPARTMENT OF HEALTH

Air Pollution Control Division

Telephone: (303) 331-8511

EMISSION PERMIT

PERMIT NO. 87EP230

DATE ISSUED: December 20, 1988

ISSUED TO: DIGITAL EQUIPMENT CORPORATION

INITIAL APPROVAL ☐

FINAL APPROVAL ☒

THE SOURCE TO WHICH THIS PERMIT APPLIES IS DESCRIBED AND LOCATED AS FOLLOWS:

A computer peripherals manufacturing facility located at 305 Rockrimmon Blvd., Colorado Springs, El Paso County, Colorado.

THE SPECIFIC EQUIPMENT OR ACTIVITY SUBJECT TO THIS PERMIT INCLUDES THE FOLLOWING:

Operation of two (2) natural gas-fired water boilers, HB Smith G28-W-B, located in the Customer Support Center. The units are for space heating purposes and capable of using oil as fuel during supply curtailment of natural gas.

THIS PERMIT IS GRANTED SUBJECT TO ALL RULES AND REGULATIONS OF THE COLORADO AIR QUALITY CONTROL COMMISSION AND THE COLORADO AIR QUALITY CONTROL ACT C.R.S. (25-7-101 et seq), TO THOSE GENERAL TERMS AND CONDITIONS SET FORTH ON THE REVERSE SIDE OF THIS DOCUMENT AND THE FOLLOWING SPECIFIC TERMS AND CONDITIONS:

1. Visible emissions shall not exceed 20% opacity.
2. Emissions of air pollutants shall not exceed the following limitations (as calculated in the Division's preliminary analysis):

Particulate Matter:	3.09 lbs./hour and 0.03 tons/year.
Sulfur Dioxide:	0.01 lbs./hour and 0.01 tons/year.
Nitrogen Oxides:	1.08 lbs./hour and 0.96 tons/year.
Volatile Organic Compounds:	0.06 lbs./hour and 0.06 tons/year.
Carbon Monoxide:	0.22 lbs./hour and 0.20 tons/year.
Particulate matter emission limitation is based on 0.34 lb per million BTU per unit.	

-continued-

*filed
12-22-88*


DIGITAL EQUIPMENT CORPORATION
Emission Permit No. 87EP230
Final Approval
Page 2.

3. This source shall be limited to a maximum consumption rate as listed below and all other activities, operational rates and numbers of equipment as stated in the application. Annual records of the actual consumption rate shall be maintained by the applicant and made available to the Division for inspection upon request.

Consumption of natural gas shall not exceed 5420.0 scf/hour
or 9.54 million scf/year for each boiler.

4. The permit number shall be clearly marked on the subject equipment for ease of identification.

By:


Review Engineer
Abe Vasquez

By:


James S. Geier, P.E., Chief
New Source Review Section
Stationary Sources Program
Air Pollution Control Division

(P-87/de)