



STATE OF
COLORADO

Khan - CDPHE She Her, Zeenath <zeenath.khan@state.co.us>

CO0150500 HARTMAN TOWN OF - TC+ Requirements

1 message

Khan - CDPHE She Her, Zeenath <zeenath.khan@state.co.us>

Thu, Jan 30, 2025 at 2:04 PM

To: Tammy Swisher <hartmantownhall@gmail.com>

Cc: Kyra Gregory - CDPHE <kyra.gregory@state.co.us>

Hello Juanna,

Thank you for your time on our phone call earlier today.

As we discussed, a water sample from the Town of Hartman ("System") collected on 01/29/2025 (reported on 01/30/2025) has results showing total coliform (TC) bacteria.

For each routine TC positive sample, the System is now required to collect 3 total coliform repeat samples (and report chlorine residuals with each sample) within the distribution system **on or before Friday, January 31st 2025**:

- 1 at the original positive tap (facility ID: DS001, sample ID: RPOR)
- 1 upstream within 5 service connections (facility ID: DS001, sample ID: RPUP)
- 1 downstream within 5 service connections (facility ID: DS001, sample ID: RPDN)

The System must also collect 1 raw/source water sample (**on or before Friday, January 31st 2025**; these raw/source water samples must be collected before any treatment is applied and must be tested for both total coliform and E. coli.

- Example for No 1 Well= facility ID: 001, sample ID: 001

Additionally, there may be monitoring and reporting violations issued for failure to collect the required follow-up samples within 24 hours and a Level 1 Assessment will be issued.

Please ensure that best practices are used when collecting these repeat samples. Below are some collection procedure tips:

- Remove any attachments on the faucet
- Sterilize the tap
- Allow water to flow for 5 minutes prior to sampling
- Reduce flow to about the thickness of a pencil
- Do not rinse or overfill the collection container
- Do not touch the inside of the sample bottle or cap. It is best to wear gloves and not set the cap down.
- Avoid collecting from outdoor taps if possible; bathroom or kitchen faucets are ideal.

Please let me know if you have any questions.

Respectfully,

Zeenath Khan

She/Her/Hers ([Why pronouns matter](#))

Compliance Specialist

Drinking Water Compliance Assurance Section

P 720-254-1393 | F 303-758-1398

4300 Cherry Creek Drive South, Denver, CO 80246

zeenath.khan@state.co.us | wqcdcompliance.com



COLORADO
Water Quality Control Division
Department of Public Health & Environment

24-hour Environmental Release/Incident Report Line: 1-877-518-5608
Total Coliform Positive or Nitrate Above 10 mg/L Reporting Line: 303-692-3308