



El Paso
Fox/myer

COLORADO DEPARTMENT OF HEALTH

Air Pollution Control Division

Telephone: (303) 331-8511

EMISSION PERMIT

PERMIT NO. 86EP185

INITIAL APPROVAL ☒

DATE ISSUED: SEPTEMBER 17, 1986

FINAL APPROVAL ☐

ISSUED TO:

DIGITAL EQUIPMENT CORPORATION

THE SOURCE TO WHICH THIS PERMIT APPLIES IS DESCRIBED AND LOCATED AS FOLLOWS:

*Disk Drive manufacturing facility located at 301
Rockrimmon Blvd., South, Colorado Springs, El
Paso County, Colorado.*

THE SPECIFIC EQUIPMENT OR ACTIVITY SUBJECT TO THIS PERMIT INCLUDES THE FOLLOWING:

*Three (3) boilers: Cleaver Brooks Model CB 200-80, SNL75618
Kewanee Model M265KX, SN622211
Kewanee Model M265KX, SN622212
Each unit has dual-fuel capability, (natural gas or No. 2
fuel oil).*

THIS PERMIT IS GRANTED SUBJECT TO ALL RULES AND REGULATIONS OF THE COLORADO AIR QUALITY CONTROL COMMISSION AND THE COLORADO AIR QUALITY CONTROL ACT C.R.S. 1973 (25-7-101 et seq), TO THOSE GENERAL TERMS AND CONDITIONS SET FORTH ON THE REVERSE SIDE OF THIS DOCUMENT AND THE FOLLOWING SPECIFIC TERMS AND CONDITIONS:

1. *Visible emissions shall not exceed 20% opacity.*
2. *Emissions of air pollutants shall not exceed the following limitations (as calculated in the Division's preliminary analysis):*

<i>Particulate Matter</i>	<i>0.09 lbs./hour and 0.67 tons/year.</i>
<i>Sulfur Dioxide:</i>	<i>3.13 lbs./hour and 0.55 tons/year.</i>
<i>Nitrogen Dioxide:</i>	<i>0.87 lbs./hour and 1.40 tons/year.</i>
<i>Volatile Organic Compounds:</i>	<i>0.04 lbs./hour and 0.07 tons/year.</i>
<i>Carbon Monoxide:</i>	<i>0.22 lbs./hour and 0.29 tons/year.</i>

*The source shall comply with SO₂ emission limitation of 0.8 lbs. SO₂ per million BTU of oil heat input for oil-fired operation.
(Regulation 6 Subpart B).*

*mailed
9-19-86*

3. This source shall be limited to a maximum consumption rate as listed below and all other activities, operational rates and numbers of equipment as stated in the application. Annual records of the actual consumption rate shall be maintained by the applicant and made available to the Division for inspection upon request.

Consumption of natural gas shall not exceed 10.4 thousand scf/hour or 25 million scf/year.

Consumption of No. 2 fuel oil shall not exceed 63.1 gal./hour or 15.0 thousand gal/year.

4. The permit number shall be clearly marked on the subject equipment for ease of identification.

5. Construction of this source must commence within 18 months of initial approval permit issuance or within 18 months of the start-up-date stated in the application. If commencement does not occur within the stated time frame the permit will expire on MARCH 17, 1988 (See General Condition No. 6., Item 1 on the reverse side of the first page of this permit).

By: _____

Abe Vasquez
Review Engineer
Abe Vasquez

By: _____

James S. Geier
James S. Geier, P.E., Chief
New Source Review Section
Stationary Sources Program
Air Pollution Control Division